

Water Line Requirements / New Tap

- 1.** Need a 3/4 inch minimum diameter approved pipe material (PVC below ground use only, Copper, Pex, CPVC, etc...)

- 2.** Needs to be at least twelve inches below ground.
Leave open in three places.

- 3.** Need cut-off valve within three feet of crawl-space access or two feet outside foundation.

- 4.** Install thermal expansion tank.

- 5.** Install pressure-reducing valve.

- 6.** Ensure existing lines disconnected from existing water source to prevent cross-contamination.

- 7.** When the above requirements are completed and available for inspection, or for any questions concerning these requirements contact **Burke County Building Inspections Dept. at 828-764-9020 for an inspection.**